



This document is to certify that the materials listed below were examined and tested by a third-party laboratory* and proven to satisfy the requirements of ASTM F2772-09 “Standard Specification for Athletic Performance Properties of Indoor Sports Floor Systems.”

Specific tests included in ASTM F2772-09 are as follows:

- EN 12235/CI “Determination of Vertical Ball Rebound Behavior” – minimum requirement of 90% basketball rebound.
- ASTM F2569 “Test Method for Evaluating the Force Reduction Properties of Surfaces for Athletic Use” (also covered in EN 14808) – classification of material as follows:
 - Class 1 -- 10% to 21% (inclusive)
 - Class 2 -- 22% to 33% (inclusive)
 - Class 3 – 34% to 45% (inclusive)
 - Class 4 – 46% to 57% (inclusive)
 - Class 5 – 58% and greater

Material Tested	EN 12235 (Ball Rebound)	ASTM F2569 / EN 14808 (Force Reduction)
Everlast 10% color (6mm)	Pass	Class 1
Everlast 10% color (8mm)	Pass	Class 1
Everlast 10% color (9mm)	Pass	Class 1
Everlast Performance 4+4	Pass	Class 1
Everlast Performance 4+6	Pass	Class 1
Everlast Performance 4+8	Pass	Class 2
7619 Underlayment (8mm)	Pass	Class 2
7619 Underlayment (10mm)	Pass	Class 2
7619 Underlayment (12mm)	Pass	Class 2
6015H Underlayment (4mm)	Pass	Class 1
6015H Underlayment (6mm)	Pass	Class 1
6015H Underlayment (7mm)	Pass	Class 2
6015H Underlayment (9mm)	Pass	Class 2
4735 Underlayment (12mm)	Pass	Class 3

*Testing performed by Labosport, Derbyshire, England, Report #UK 10-0039, dated 6-Mar-10